

		CLIENT : ATOFINA / KRONOCHEM		JOB		REVIZIA			
		LOCATION : Villers Saint Paul - FR / SEBES - RO		2001		A	B	D	E
		PLANT : Formocol VSP 757		SPEC. N. 2001.IS.015					
SPECIF. INDIVIDUALA INSTRUMENTE				Pg 4 of 6		COMPLETAT KRONOCH.		DATA 22/03/2017	
SPECIFICATIE DEBITMETRU MASIC									
NUMAR ETICHETA		(*) FT/DT-204		(*) FT/DT-254					
SPECIFICATIE PROIECT		DN50-P-2252-E		DN50-P-2252-E					
C	INSTALARE	LOCAL		LOCAL					
N	FLUID	FORMALDEHIDA 50%		FORMALDEHIDA 50%					
D	STARE FLUID	<input checked="" type="checkbox"/> LIQUID <input type="checkbox"/> GAZ <input type="checkbox"/>		<input checked="" type="checkbox"/> LIQUID <input type="checkbox"/> GAZ <input type="checkbox"/>					
D	COROSIV/CONT. DE SOLID	<input type="checkbox"/> DA <input checked="" type="checkbox"/> NU <input type="checkbox"/>		<input type="checkbox"/> DA <input checked="" type="checkbox"/> NU <input type="checkbox"/>					
E	DEBIT (Kg/h)	300 min.	12000 norm.	15000 max.	300 min.	12000 norm.	15000 max.		
O	PRESIUNE (barg)	3,8 min.	norm.	max.	3,8 min.	norm.	max.		
P	TEMPERATURA (°C)	70 min.	norm.	80 max.	70 min.	norm.	80 max.		
E									
R	GREUTATE SPECIFICA	1163		1163					
A	CONDUCTIVITATE (microS/cm)								
R	VISCOSITATE (C.P.)	1.6		1.6					
E	TEMP. MEDIU AMB. (°C)	-20 + +40		-20 + +41					
	MAX. DIFF.PRESIUNE (bar)								
E	TIP ELEMENT	<input checked="" type="checkbox"/> CONTOR PRIMAR		<input checked="" type="checkbox"/> CONTOR PRIMAR					
L	MOUNTARE ON LINE	<input type="checkbox"/> VERTICAL <input checked="" type="checkbox"/> ORIZ.		<input type="checkbox"/> VERTICAL <input checked="" type="checkbox"/> ORIZ.					
E	CONEXIUNE CORP	<input checked="" type="checkbox"/> FLGD <input type="checkbox"/> FILETAT		<input checked="" type="checkbox"/> FLGD <input type="checkbox"/> FILETAT					
M	DN/PN CORP CONEX./CLASIF.	40	40	40	40				
E	STANDARD	<input type="checkbox"/> ANSI <input type="checkbox"/> UNI <input checked="" type="checkbox"/> DIN		<input type="checkbox"/> ANSI <input type="checkbox"/> UNI <input checked="" type="checkbox"/> DIN					
N	MATERIAL FLANSA	<input checked="" type="checkbox"/> AISI 316		<input checked="" type="checkbox"/> AISI 316					
T	MAT. TUB MASURARE	<input checked="" type="checkbox"/> AISI 316		<input checked="" type="checkbox"/> AISI 316					
P	TIP CARCASA	<input checked="" type="checkbox"/> EEx-ib IIB/IIC T2		<input checked="" type="checkbox"/> EEx-ib IIB/IIC T2					
R	NORMA ELECTRICA	<input checked="" type="checkbox"/> CENELEC		<input checked="" type="checkbox"/> CENELEC					
I	TIP EXECUTIE ELECTRICA	<input checked="" type="checkbox"/> IP 65 min		<input checked="" type="checkbox"/> IP 65 min					
M	CONEXIUNE ELECTRICA	<input checked="" type="checkbox"/> 1/2" NPT-F		<input checked="" type="checkbox"/> 1/2" NPT-F					
A	ALIM. ELECTRICA	<input checked="" type="checkbox"/> 24 V dc		<input checked="" type="checkbox"/> 24 V dc					
R	ACURATETE :MASA/DENSIT.	<input checked="" type="checkbox"/> ± 0,15 % Scala <input type="checkbox"/> ± 0,5%		<input checked="" type="checkbox"/> ± 0,15 % Scala <input type="checkbox"/> ± 0,5%					
	MODEL	CMF200M381NACZFZZZ		CMF200M381NACZFZZZ					
E	TIP	<input checked="" type="checkbox"/> CONVERTER		<input checked="" type="checkbox"/> CONVERTER					
L	SEMNAL INTRARE	<input checked="" type="checkbox"/> DE LA MASUR.		<input checked="" type="checkbox"/> DE LA MASUR.					
E	SEMNAL IESIRE	<input checked="" type="checkbox"/> 4 -20 mA		<input checked="" type="checkbox"/> 4 -20 mA					
M	TIP CARCASA	<input checked="" type="checkbox"/> EEx-d IIB T2		<input checked="" type="checkbox"/> EEx-d IIB T2					
E	NORMA ELECTRICA	<input checked="" type="checkbox"/> CENELEC		<input checked="" type="checkbox"/> CENELEC					
N	REPETABILITATE	<input checked="" type="checkbox"/> ± 0,25% Scala		<input checked="" type="checkbox"/> ± 0,25% Scala					
T	CONEXIUNE ELECTRICA	N°2 Ø 1/2" NPT-F		N°2 Ø 1/2" NPT-F					
S	ALIM. ELECTRICA	<input checked="" type="checkbox"/> 24 V dc		<input checked="" type="checkbox"/> 24 V dc					
E	MONTARE	<input checked="" type="checkbox"/> JUG <input type="checkbox"/> CABINET		<input checked="" type="checkbox"/> JUG <input type="checkbox"/> CABINET					
C	CABLU SPECIAL	<input checked="" type="checkbox"/> 3 m		<input checked="" type="checkbox"/> 3 m					
	MODEL	2700R11DCFFZZZ		2700R11DCFFZZZ					
	VANZATOR	MICROMOTION		MICROMOTION					
	COMANDA N°	2001-126		2001-126					
NOTA : (*) ACEST INSTRUMENT FUNCTIONEAZA IN DOUA CONDITII DE OPERARE (1) DOUA SEMNALE: MASA, DENSITATE									
E	TRADUS			KRONOCH.				22.03.2017	
D	RELEVEU			MAPCO				10/10/02	
C									
B	REV.B			CC				30.04.2002	
A	ELIBERAT			PSC				25.03.2002	
Rev	DESCRIERE			COMPL.	VERIF.	APROBAT	DATA		