







Sistem paratrasnet cu
dispozitiv de amorsare (P.D.A.)
Nivel protectie INTARIT-I
Clasa I
Montat la 3 m peste
cota maxima a hornului
Raza de protectie $R_p=41m$
Conductoare de coborare - minim 4
pe exterior

LEGENDA INSTALATIE DETECTIE SI SEMNALIZARE INCENDIU

-  Detector de fum optic
-   Bariera de fum
-  

| | | | | |
|---------------------------|---|-----------|--|--|
| | | | | |
| VERIFICATOR | NUME | SEMNATURA | CERINTA | REFERAT / EXPERTIZA NR. / DATA |
| |  S.C. "ARHING" PROIECTARE-CERCETARE-EXPERTIZARE IN CONSTRUCTII, INSTALATII Tg.Mures str. Gh.Doja nr.47/A | | | Beneficiar : Municipiul Sebes |
| SEF PROIECT | arh.SZEKERES I. | | SCARA 1:100 | PR.NR. XXXI-1118 /2021 |
| SEF PROIECT MC | dr.ing. Alexandru Mircea IATAN | | DATA 2021. | FAZA: D.A.L.I. |
| PROIECTAT SPECIALITATE | ing. M. Robert POP | | | PL.NR: IE 05 |
| | | | RESTAURARE, CONSOLIDARE SI PUNERE IN VALOARE CASA ZAPOLYA – MUZEU IOAN RAICA, MUNICIPIUL SEBES Str. Piata Primariei nr. 3, Sebes, jud. Alba | |
| | | | PROPUNERE PLAN INVELITOARE | |